## COOL SQUARE

SISTEMALUX

MODEL : S7280


IMPORTANT - READ CAREFULLY BEFORE INSTALLING FIXTURE. RETAIN THESE INSTRUCTIONS FOR FUTURE REFERENCE.

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE AND ALL APPLICABLE LOCAL CODES, BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT, AND THE HAZARDS INVOLVED. PROPER GROUNDING IS REQUIRED FOR SAFETY.

▲ DISCONNECT THE MAIN LINE BEFORE WIRING SECONDARY CONNECTORS.

## DIRECT FEED INSTALLATION (DF) - LOW VOLTAGE (24V) REMOTE DRIVER (REM)


- A- PREPARE SURFACE FOR INSTALLATION (SEE DIMENSIONS BELOW). \*INSERT (2) ANCHOR SCREWS (NOT INCLUDED) IF NECESSARY.
- B- UNFASTEN THE SET SCREWS WITH AN ALLEN KEY (INCLUDED) TO REMOVE THE FIXTURE FROM THE BASE.
- DO NOT COMPLETELY REMOVE THE SET SCREWS.
- C- INSERT THE LIQUID TIGHT GROMMET (INCLUDED) INTO FIXTURE BASE.
- D- PASS EXTERIOR CABLE THROUGH LIQUID TIGHT GROMMET.
- E- USING (2) #8 SCREWS (NOT INCLUDED) AND WASHERS (INCLUDED), INSTALL THE FIXTURE BASE TO THE WALL.
- \*TO GUARANTEE A WATERTIGHT INSTALLATION, MAKE SURE TO INSERT THE WASHERS (SEE BELOW).
- F- MAKE ALL NECESSARY WIRE CONNECTIONS INTO THE CONNECTOR BLOCK USING A SCREWSDRIVER (SEE WIRING DIAGRAM BELOW).
- G- FASTEN THE FIXTURE ON ITS BASE WITH THE SET SCREWS WITH AN ALLEN KEY (INCLUDED).



9320 Boul. St-Laurent, suite 100, Montréal (Québec) Canada H2N 1N7 P.: 514.523.1339 F.: 514.525.6107 www.sistemalux.com M DISCONNECT THE MAIN LINE BEFORE WIRING SECONDARY CONNECTORS.

4" JUNCTION BOX INSTALLATION (JB) LOW VOLTAGE (24V) REMOTE DRIVER (REM) OR INTEGRAL DRIVER 120-277V (UNV)

- A- FIX THE UNIVERSAL CROSSBAR TO THE 4" JUNCTION BOX USING (2) PHILLIPS SCREWS (INCLUDED). MAKE SURE THE UNIVERSAL CROSSBAR IS PROPERLY ALIGNED.
- B- INSTALL THE MOUNTING PLATE ON THE UNIVERSAL CROSSBAR USING (2) PHILLIPS SCREWS (INCLUDED).
- C- UNFASTEN THE SET SCREWS WITH AN ALLEN KEY (INCLUDED) TO REMOVE THE FIXTURE FROM THE BASE. DO NOT COMPLETELY REMOVE THE SET SCREWS.
- D- MAKE WIRE CONNECTIONS (FOLLOWING POLARITY MARKING) USING TWIST CONNECTORS (NOT INCLUDED)
- E- USING (2) PHILLIPS SCREWS AND WASHERS (INCLUDED), INSTALL THE FIXTURE BASE TO THE MOUNTING PLATE.
- \*TO GUÀRANTEE A WATERTIGHT INSTALLATION, MAKE SURE TO INSERT THE WASHERS (SEE BELOW).
- F- FASTEN THE FIXTURE ON ITS BASE WITH THE SET SCREWS WITH AN ALLEN KEY (INCLUDED).




SISTEMALUX

<sup>9320</sup> Boul. St-Laurent, suite 100, Montréal (Québec) Canada H2N 1N7 P.: 514.523.1339 F.: 514.525.6107 www.sistemalux.com

M DISCONNECT THE MAIN LINE BEFORE WIRING SECONDARY CONNECTORS.

## 2" JUNCTION BOX INSTALLATION (J2) LOW VOLTAGE (24V) REMOTE DRIVER (REM) OR INTEGRAL DRIVER 120-277V (UNV)

- A- PREPARE SURFACE FOR INSTALLATION (SEE DIMENSIONS BELOW). \*INSERT (2) ANCHOR SCREWS (NOT INCLUDED) IF NECESSARY. MAKE SURE THE JUNCTION BOX IS PROPERLY ALIGNED.
- B- UNFASTEN THE SET SCREWS WITH AN ALLEN KEY (**INCLUDED**) TO REMOVE THE FIXTURE FROM THE BASE. DO NOT COMPLETELY REMOVE THE SET SCREWS.
- C- MAKE WIRE CONNECTIONS (FOLLOWING POLARITY MARKING) USING TWIST CONNECTORS (NOT INCLUDED)
- D- USING (2) PHILLIPS SCREWS AND WASHERS (INCLUDED), INSTALL THE FIXTURE BASE TO THE WALL.
- \*TO GUARANTEE A WATERTIGHT INSTALLATION, MAKE SURE TO INSERT THE WASHERS (SEE BELOW).
- E- FASTEN THE FIXTURE ON ITS BASE WITH THE SET SCREWS WITH AN ALLEN KEY (INCLUDED).



INS-477